

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0202-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HCB03CF001	Range	0 ~ 3500
Instrument Description	SOOTBLOWER STEAM FLOW	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX130A	Max. Error	0.5 %
Serial Number	91V501640	Cal. Date	29-05-2024
Instrument Location	BOILER 9TH FLOOR		

Environment Condition

Temperature 27.5 °C
Humidity 50 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0	4.000	4.001	0.001	0.006	Pass						
875	8.000	8.001	0.001	0.006	Pass						
1750	12.000	12.000	0.000	0.000	Pass						
2625	16.000	16.000	0.000	0.000	Pass						
3500	20.000	20.001	0.001	0.006	Pass						
3500	20.000	20.001	0.001	0.006	Pass						
2625	16.000	16.001	0.001	0.006	Pass						
1750	12.000	12.000	0.000	0.000	Pass						
875	8.000	8.000	0.000	0.000	Pass						
0	4.000	4.001	0.001	0.006	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Fluke Pressure Module 750PD27	6087359	S. 23 014 459	09-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 30-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT. Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

