

## REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 1224-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HCB12AA801 Power Supply 380 VAC  
Instrument Description WALL SOOTBLOWER (FRONT & RIGHT) Stroke 51 mm  
WARMING DRAIN VALVE  
Manufacture AUMA  
Model SA.07.6.F04 Inspection Date 06-06-2024  
Serial Number 51MA01262  
Instrument Location Boiler 5th Floor

### Environment Condition

Temperature 30.1 °C Traveling Time  
Humidity 42 % RH Open to Close 18.85 s  
Close to Open 19.24 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
Gearbox Condition  OK  Not OK

### Remark

### Test Equipment

Description Serial Number Certificate Number Calibration Date  
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
Date of issue, 07-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA  
Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas  
This certificate applies only for the item specified above  
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval  
\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang  
This certificate is valid if it has approved and signed by authorized person

