

CERTIFICATE OF CALIBRATION
TEMPERATURE SWITCH

Certificate No. : 0558-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60HDE01CT302

Instrument Description

A1S2 T/R unit Oil Temperature Gauge with Switch

Manufacture

SENSBEY

Model / Serial Number

OS-SL-150-OP / 22K4422

Instrument Location

ESP

Set 95

Reset 93

Unit °C

Cal. Date 26-06-2026

Environment Condition

Temperature

31.4 °C

Humidity

73 % RH

Calibration Result

Data Reading (Switch)

As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
94.930	92.860	2.070			
94.930	92.860	2.070			
94.930	92.860	2.070			

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Dryblock Isotech Fast Cal

Serial Number

311520-1

Certificate Number

08130/GQI-Sert/09/25

Calibration Date

28-08-2025

TRUE RMS Multimeter Fluke 87V

45910296

UAL/04843/26

23-04-2026

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 27-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

Ivan Hidayat

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

