

## CERTIFICATE OF CALIBRATION

## TEMPERATURE SWITCH

Certificate No. : 0562-26-HI-CAL-10

## Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&amp;6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

## Instrument Information

KKS No.

60HDE01CT306

Instrument Description

A3S2 T/R unit Oil Temperature Gauge with Switch

Manufacture

SENSBEY

Model / Serial Number

OS-SL-150-OP / 22K4443

Instrument Location

ESP

Set

95

Reset

93

Unit

°C

Cal. Date

26-06-2026

## Environment Condition

Temperature

29.7 °C

Humidity

54 % RH

## Calibration Result

## Data Reading (Switch)

| As Found |        |          | As Left |        |          |
|----------|--------|----------|---------|--------|----------|
| Set      | Reset  | Deadband | Set     | Reset  | Deadband |
| 98.850   | 96.450 | 2.400    | 95.240  | 93.160 | 2.080    |
| 98.850   | 96.450 | 2.400    | 95.240  | 93.160 | 2.080    |
| 98.850   | 94.450 | 4.400    | 95.240  | 93.160 | 2.080    |

## Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



## Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

Dryblock Isotech Fast Cal

311520-1

08130/GQI-Sert/09/25

28-08-2025

TRUE RMS Multimeter Fluke 87V

45910296

UAL/04843/26

23-04-2026

## Calibration Method

0002/SOP\_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter &amp; Temperature Switch

This certificate comprises 2 pages

Date of issue, 27-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA

Ivan Hasan Ashari

INDONESIA

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

