

CERTIFICATE OF CALIBRATION
TEMPERATURE SWITCH

Certificate No. : 0566-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60HDE02CT304

B2S2 T/R unit Oil Temperature Gauge with Switch

SENSBEY

OS-SL-150-OP / 22K4426

ESP

Set

Reset

Unit

Cal. Date

95

93

°C

26-06-2026

Environment Condition

Temperature

29.7 °C

Humidity

54 % RH

Calibration Result

Data Reading (Switch)

As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
98.670	95.520	3.150	95.010	94.070	0.940
98.670	95.520	3.150	95.010	94.070	0.940
98.670	95.520	3.150	95.010	94.070	0.940

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Serial Number

Certificate Number

Calibration Date

TRUE RMS Multimeter Fluke 87V

45910296

UAL/04843/26

23-04-2026

Dryblock Isotech Fast Cal

311520-1

08130/GQI-Sert/09/25

28-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 27-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

