

CERTIFICATE OF CALIBRATION
TEMPERATURE SWITCH

Certificate No. : 0567-26-HI-CAL-10

Customer Information

Company Name

PT. Bhumi Jati Power

Address

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.

C-BJP-26-0004-OTH

Instrument Information

KKS No.

60HDE02CT305

Instrument Description

B3S1 T/R unit Oil Temperature Gauge with Switch

Manufacture

SENSBEY

Model / Serial Number

OS-SL-150-OP / 22K4435

Instrument Location

ESP

Set	95
Reset	93
Unit	°C
Cal. Date	26-06-2026

Environment Condition

Temperature

29.7 °C

Humidity

54 % RH

Calibration Result

Data Reading (Switch)					
As Found			As Left		
Set	Reset	Deadband	Set	Reset	Deadband
98.100	95.200	2.900	95.630	93.510	2.120
98.100	95.200	2.900	95.630	93.510	2.120
98.100	95.200	2.900	95.630	93.510	2.120

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Dryblock Isotech Fast Cal	311520-1	08130/GQI-Sert/09/25	28-08-2025
TRUE RMS Multimeter Fluke 87V	45910296	UAL/04843/26	23-04-2026

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 27-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signature

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

