

## CERTIFICATE OF CALIBRATION LEVEL RADAR

Certificate No. : 0540-24-HI-CAL-101

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFA10CL001	Range	0 ~ 29000
Instrument Description	COAL SILO A LVL	Unit	mm
Manufacture	ENDRESS HAUSER	Out. Signal	4 - 20 mA
Model	FMR57	Max. Deviation	145mm (0.5%)
Serial Number	P5003B01139	Cal. Date	12-05-2024
Instrument Location	BOILER 8TH FLOOR		

### Environment Condition

Temperature 28.3 °C  
Humidity 52 % RH

### Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result	Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result
[mm]	[mm]	[mm]					[mm]	[mm]	[mm]				
0	6089	6190	101.000	16.680	16.684	Pass							
10000	11139	11210	71.000	13.820	13.815	Pass							
15000	16129	16180	51.000	11.070	11.073	Pass							
20000	21250	21240	-10.000	8.280	8.281	Pass							
25000	26280	26190	-90.000	5.550	5.551	Pass							
29000	30020	29880	-140.000	4.000	4.001	Pass							

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER METER	1370571658	S. 23 004 596	24-03-2023

### Calibration Method

0007/SOP\_BJS/2023  
Procedure of Calibration Level Radar

This certificate comprise of 1 page  
Date of issue, 13-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,

HERVITAMA



M. Idris Nofriyanti

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

