

CERTIFICATE OF CALIBRATION LEVEL RADAR

Certificate No. : 0541-24-HI-CAL-101

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFA20CL001	Range	0 ~ 29000
Instrument Description	COAL SILO B LVL	Unit	mm
Manufacture	ENDRESS HAUSER	Out. Signal	4 - 20 mA
Model	FMR 57	Max. Deviation	145mm (0.5%)
Serial Number	P5003901139	Cal. Date	13-05-2024
Instrument Location	BOILER 8TH FLOOR		

Environment Condition

Temperature: 28.4 °C
Humidity: 52 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result	Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result
[mm]	[mm]	[mm]					[mm]	[mm]	[mm]				
5000	5866	5940	74.000	17.210	17.196	Pass							
10000	10654	10780	126.000	14.550	14.533	Pass							
15000	15540	15650	110.000	11.860	11.849	Pass							
20000	20735	20840	105.000	8.990	8.983	Pass							
25000	25719	25860	141.000	6.230	6.213	Pass							
29000	29540	29650	110.000	4.140	4.123	Pass							

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Digital Multimeter Fluke 87V	49910296	S. 22 008 273	13-07-2022

Calibration Method

0007/SOP_BJS/2023
Procedure of Calibration Level Radar

This certificate comprise of 1 page
Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Indira Nurfitriyan

Calibrated by,



Fashol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

