

CERTIFICATE OF CALIBRATION  
LEVEL SWITCH

Certificate No. : 1074-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60HFA20CL302  
Instrument Description COAL SILO B LEVEL SWITCH 2  
Manufacture ENDRESS HAUSER  
Model / Serial Number FT156 / P1000D010FF  
Instrument Location BOILER 7TH FLOOR

Type of Testing Function Test  
Cal. Date 29-05-2026

## Environment Condition

Temperature 30 °C Humidity 65 % RH

## Calibration Result

| Data Reading (Switch) |               |               |               |
|-----------------------|---------------|---------------|---------------|
| As Found              |               | As Left       |               |
| Open to Close         | Close to Open | Open to Close | Close to Open |
| OK                    | OK            |               |               |
| OK                    | OK            |               |               |
| OK                    | OK            |               |               |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                   | Serial Number | Certificate Number | Calibration Date |
|-------------------------------|---------------|--------------------|------------------|
| TRUE RMS Multimeter Fluke 87V | 45910296      | UAL/04843/26       | 23-04-2026       |

## Calibration Method

0004/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Level Switch

This certificate comprises 2 pages  
Date of issue, 03-06-2026

Customer Signature,

Erfan Nanda Gifari

HERVITAMA

INDONESIA  
Ivan Hasan Ashari

Calibrated by,

M. Fauziq Nur Fitriyan

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person