

CERTIFICATE OF CALIBRATION LEVEL SWITCH

Certificate No. : 0488-24-HI-CAL-10I

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HFA30CL301 Type of Testing Function Test
Instrument Description COAL SILO C LEVEL SWITCH 1 Cal. Date 19-05-2024
Manufacture ENDRESS HAUSER
Model FT156
Serial Number P30028010FF
Instrument Location BOILER 7TH FLOOR

Environment Condition

Temperature 27 °C
Humidity 50 % RH

Calibration Result

Data Reading (Switch)			
As Found		As Left	
Switch	Result	Switch	Result
Set (NC)	OK		
Reset (NO)	OK		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022

Calibration Method

0008/SOP_BJS/2023
Procedure of Calibration Level Switch

This certificate comprise of 1 page
Date of issue, 20-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiqurrahman

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

