

## CERTIFICATE OF CALIBRATION LEVEL SWITCH

Certificate No. : 0494-24-HI-CAL-10I

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HFA30CL302 Type of Testing Function Test  
 Instrument Description COAL SILO A LEVEL SWITCH 2 Cal. Date 19-05-2024  
 Manufacture ENDRESS HAUSER  
 Model FT156  
 Serial Number P1000F010FF  
 Instrument Location BOILER 7TH FLOOR

### Environment Condition

Temperature 27.1 °C  
 Humidity 50 % RH

### Calibration Result

Data Reading (Switch)			
As Found		As Left	
Switch	Result	Switch	Result
Set (NC)	OK		
Reset (NO)	OK		

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022

### Calibration Method

0008/SOP\_BJS/2023  
 Procedure of Calibration Level Switch

This certificate comprise of 1 page  
 Date of issue, 20-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Indonegriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

*\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang*

*This certificate is valid if it has approved and signed by authorized person*

