

CERTIFICATE OF CALIBRATION LEVEL RADAR

Certificate No. : 0543-24-HI-CAL-10I

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFA40CL001	Range	0 - 29000
Instrument Description	COAL SILO D LVL	Unit	mm
Manufacture	ENDRESS HAUSER	Out. Signal	4 - 20 mA
Model	FMR 57	Max. Deviation	145mm (0.5%)
Serial Number	P5003D01139	Cal. Date	13-05-2024
Instrument Location	BOILER 8TH FLOOR		

Environment Condition

Temperature 28.2 °C
 Humidity 51 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result	Input	Std Output	Output UUT	Deviation	mA 1	mA 2	Result
[mm]	[mm]	[mm]					[mm]	[mm]	[mm]				
5000	5726	5870	144.000	17.250	17.252	Pass							
10000	10594	10630	36.000	14.550	14.580	Pass							
15000	15726	15740	14.000	11.810	11.998	Pass							
20000	20896	20920	24.000	8.950	8.937	Pass							
25000	25719	25860	141.000	6.230	6.213	Pass							
29000	29429	29560	131.000	4.190	4.171	Pass							

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
FIK-87-V MULTIMETER	45910296	S. 22 008 273	13-07-2022

Calibration Method

0007/SOP_BJS/2023
 Procedure of Calibration Level Radar

This certificate comprise of 1 page
 Date of issue, 14-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

