

CERTIFICATE OF CALIBRATION LEVEL SWITCH

Certificate No. : 0495-24-HI-CAL-101

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFA40CL302	Type of Testing	Function Test
Instrument Description	COAL SILO A LEVEL SWITCH 2	Cal. Date	19-05-2024
Manufacture	ENDRESS HAUSER		
Model	FT156		
Serial Number	P10011010FF		
Instrument Location	BOILER 7TH FLOOR		

Environment Condition

Temperature: 27.1 °C
 Humidity: 50 % RH

Calibration Result

Data Reading (Switch)			
As Found		As Left	
Switch	Result	Switch	Result
Set (NC)	OK		
Resel (NO)	OK		

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022

Calibration Method

0008/SOP_BJS/2023
 Procedure of Calibration Level Switch

This certificate comprise of 1 page
 Date of issue, 20-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Nur Atriyanto

Calibrated by,



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

