

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0573-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFB50CT001
 Instrument Description COAL FEEDER E TEMPERATURE
 Manufacture ENDRESS+HAUSER
 Model / Serial Number - / -
 Instrument Location BOILER 3RD FLOOR

Range 0 ~ 100
 Unit °C
 Out. Signal 4 - 20 mA
 Max. Deviation 1.7 °C (JIS)
 Cal. Date 08-06-2026
 Temp. Element Thermocouple Type E

Environment Condition

Temperature 29 °C Humidity 61 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.800	0.200	Pass					
45	44.600	45.300	0.700	Pass					
50	49.500	50.200	0.700	Pass					
75	74.900	75.100	0.200	Pass					
100	99.900	100.200	0.300	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
 Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Temperature Calibrator Fluke 725	2815000	2256/25/KAL/06/2025	23-06-2025
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025
 Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
 Date of issue, 12-06-2026

Customer Signature,



Erfan Nanda Gifari

HERVITAMA
 Approved by,



INDONESIA
 Ivan Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person