

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0415-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFC10CP001	Range	0 ~ 350
Instrument Description	PULVERIZER A OUTLET PRESSURE	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501692	Cal. Date	25-05-2024
Instrument Location	BOILER 3RD FLOOR		

Environment Condition

Temperature: 27.2 °C
Humidity: 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
0.0	4.000	4.008	0.008	0.050	Pass						
87.5	8.000	8.000	0.000	0.000	Pass						
175.0	12.000	12.005	0.005	0.031	Pass						
262.5	16.000	16.003	0.003	0.019	Pass						
350.0	20.000	20.004	0.004	0.025	Pass						
350.0	20.000	20.004	0.004	0.025	Pass						
262.5	16.000	15.999	-0.001	-0.006	Pass						
175.0	12.000	12.003	0.003	0.019	Pass						
87.5	8.000	7.999	-0.001	-0.006	Pass						
0.0	4.000	4.005	0.005	0.031	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 26-05-2024

Customer Signature,



Ayrtan Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
This certificate applies only for the item specified above
Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
This certificate is valid if it has approved and signed by authorized person

