

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0553-24-HI-CAL-10D

### Customer Information

Company Name  
 Address  
 Contract No.

PT. Bhumi Jati Power  
 PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 C-BJP-24-0013-OTH

### Instrument Information

KKS No.  
 Instrument Description  
 Manufacture  
 Model  
 Serial Number  
 Instrument Location

60HFC10CT003  
 PULVERIZER A OUTLET TEMPERATURE 3  
 YAMARI  
 TM  
 5451738  
 BOILER 2ND FLOOR

Range 0 ~ 200  
 Unit °C  
 Out. Signal 4 - 20 mA  
 Max. Deviation 2 °C  
 Cal. Date 08-05-2024  
 Temp. Element Thermocouple Type E

### Environment Condition

Temperature  
 Humidity

28.8 °C  
 58 % RH

### Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.000	0.000	Pass					
50	50.020	50.200	0.180	Pass					
100	100.000	100.800	0.800	Pass					
150	150.000	151.000	1.000	Pass					
200	200.010	201.300	1.290	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
 Date of issue, 09-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

