

CERTIFICATE OF CALIBRATION
LEVEL RADAR

Certificate No. : 1115-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC16CL001
Instrument Description PULVERIZER A LOADING OIL TANK LEVEL
Manufacture SIEMENS
Model / Serial Number 7ML 52211BC11 / PDB / KN080875
Instrument Location BOILER GROUND FLOOR

Range 0 ~ 600
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 18-06-2026

Environment Condition

Temperature 25 °C Humidity 56 % RH

Calibration Result

Data Reading (Transmitter)													
As Found							As Left						
Input	Std Distance	UUT Distance	Output UUT	Deviation	Error	Result	Input	Std Distance	UUT Distance	Output UUT	Deviation	Error	Result
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]	
900	912	910	4.147	-2.000	-0.333	Pass							
750	762	762	8.081	0.000	0.000	Pass							
600	614	617	11.948	3.000	0.500	Pass							
450	464	467	15.959	3.000	0.500	Pass							
300	311	312	20.094	1.000	0.167	Pass							

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0006/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Radar / Ultrasound

This certificate comprises 2 pages
Date of issue, 19-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

INDONESIA
Ivan Hasan Ashari

Calibrated by,

Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia
This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

