

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0138-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HFC20CP001	Range	0 ~ 350
Instrument Description	PULVERIZER B OUTLET PRESSURE	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model / Serial Number	EJX110A / 91V501693	Max. Error	0.5 %
Instrument Location	BOILER 3RD FLOOR	Cal. Date	27-05-2026

Environment Condition

Temperature 31 °C Humidity 72 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	4.032	0.032	0.200	Pass						
87.500	8.000	8.035	0.035	0.219	Pass						
175.000	12.000	12.035	0.035	0.219	Pass						
262.500	16.000	16.043	0.043	0.269	Pass						
350.000	20.000	20.042	0.042	0.263	Pass						
262.500	16.000	16.042	0.042	0.263	Pass						
175.000	12.000	12.040	0.040	0.250	Pass						
87.500	8.000	8.043	0.043	0.269	Pass						
0.000	4.000	4.030	0.030	0.188	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒	Tightness Check ☒	Corrosion Check ☒
Accessories Check ☒	Power Supply ☒	

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
 Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
 Date of issue, 03-06-2026

Customer Signature,




Erfan Nanda Gifari

Authorized Signatory,



Ivan Hasan Asih

Calibrated by,



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person