

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0555-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFC20CT002	Range	0 ~ 200
Instrument Description	PULVERIZER B OUTLET TEMPERATURE 2	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model	TM	Max. Deviation	2 °C
Serial Number	5451740	Cal. Date	08-05-2024
Instrument Location	BOILER 2ND FLOOR	Temp. Element	Thermocouple Type E

Environment Condition

Temperature 31.2 °C
 Humidity 52 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.010	39.900	-0.110	Pass					
50	50.010	50.200	0.190	Pass					
100	100.000	100.800	0.800	Pass					
150	150.000	150.900	0.900	Pass					
200	200.010	200.00	-0.010	Pass					

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 09-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. INDONE Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

