

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0141-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC24CP003
Instrument Description PULVERIZER B LUBE OIL PUMP INLET PRESSURE
Manufacture HONEYWELL
Model / Serial Number - / C4000005679489
Instrument Location BOILER 1ST FLOOR

Range 0 ~ 10
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 02-06-2026

Environment Condition

Temperature 32 °C Humidity 69 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
2.500	8.000	7.995	-0.005	-0.031	Pass						
5.000	12.000	11.991	-0.009	-0.056	Pass						
7.500	16.000	15.987	-0.013	-0.081	Pass						
10.000	20.000	19.983	-0.017	-0.106	Pass						
7.500	16.000	15.985	-0.015	-0.094	Pass						
5.000	12.000	11.990	-0.010	-0.063	Pass						
2.500	8.000	7.995	-0.005	-0.031	Pass						
0.000	4.000	4.001	0.001	0.006	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
PRESSURE MODULE FLK 750PD27	6087359	02172/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 06-06-2026

Customer Signature,



Erfan Nanda Gifari

HERVITAMA
Approved Signatory,



INDONESIA
Ivan Hasan Ashari

Calibrated by,



Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person