

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0143-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60HFC25CP012

PULVERIZER B BEARING LUBE OIL PRESSURE 2

HONEYWELL

- / C4000005679520

BOILER 1ST FLOOR

Range 0 ~ 400
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 02-06-2026

Environment Condition

Temperature

32 °C

Humidity

69 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
0.000	4.000	4.002	0.002	0.013	Pass						
100.040	8.001	8.002	0.001	0.006	Pass						
200.020	12.000	12.003	0.003	0.019	Pass						
300.060	16.002	16.002	0.000	0.000	Pass						
400.030	20.001	20.002	0.001	0.006	Pass						
300.060	16.002	16.003	0.001	0.006	Pass						
300.020	12.000	12.002	0.002	0.013	Pass						
100.040	8.001	8.002	0.001	0.006	Pass						
0.000	4.000	4.002	0.002	0.013	Pass						

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025

Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages

Date of issue, 06-06-2026

Customer Signature,

Erfan Nanda Gifari

Authorized Signatory,

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person