

## CERTIFICATE OF CALIBRATION LEVEL RADAR

Certificate No. : 1116-26-HI-CAL-10

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

### Instrument Information

KKS No. 60HFC26CL001  
Instrument Description PULVERIZER B LOADING OIL TANK LEVEL  
Manufacture SIEMENS  
Model / Serial Number 7ML 52211BC11 / PDB / KN080872  
Instrument Location BOILER GROUND FLOOR

Range 0 ~ 600  
Unit mm  
Out. Signal 4 - 20 mA  
Max. Error 0.5%  
Cal. Date 18-06-2026

### Environment Condition

Temperature 25 °C Humidity 56 % RH

### Calibration Result

| Data Reading (Transmitter) |              |              |            |           |       |        |         |              |              |            |           |       |        |
|----------------------------|--------------|--------------|------------|-----------|-------|--------|---------|--------------|--------------|------------|-----------|-------|--------|
| As Found                   |              |              |            |           |       |        | As Left |              |              |            |           |       |        |
| Input                      | Std Distance | UUT Distance | Output UUT | Deviation | Error | Result | Input   | Std Distance | UUT Distance | Output UUT | Deviation | Error | Result |
| [mm]                       | [mm]         | [mm]         | [mA]       |           | [%]   |        | [mm]    | [mm]         | [mm]         | [mA]       |           | [%]   |        |
| 900                        | 913          | 914          | 4.033      | 1.000     | 0.167 | Pass   |         |              |              |            |           |       |        |
| 750                        | 759          | 761          | 8.128      | 2.000     | 0.333 | Pass   |         |              |              |            |           |       |        |
| 600                        | 614          | 616          | 11.981     | 2.000     | 0.333 | Pass   |         |              |              |            |           |       |        |
| 450                        | 463          | 466          | 15.996     | 3.000     | 0.500 | Pass   |         |              |              |            |           |       |        |
| 300                        | 308          | 311          | 20.113     | 3.000     | 0.500 | Pass   |         |              |              |            |           |       |        |

### Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

### Standard Reference

| Description                  | Serial Number  | Certificate Number   | Calibration Date |
|------------------------------|----------------|----------------------|------------------|
| DIGITAL LASER DISTANCE METER | 18H114632      | 02169/GQI-Sert/03/26 | 09-03-2026       |
| STEEL TAPE MEASURE           | 001/L1/HI/2026 | 01231/GQI-Sert/02/26 | 09-02-2026       |

### Calibration Method

0006/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Level Radar / Ultrasound

This certificate comprises 2 pages  
Date of issue, 19-06-2026

Customer Signature,




Erfan Nanda Gifari

Authorized by,



Ivan Hasan Ashari

Calibrated by,



Faisol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person