

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0558-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

| | | | |
|------------------------|-----------------------------------|----------------|---------------------|
| KKS No. | 60HFC30CT002 | Range | 0 ~ 200 |
| Instrument Description | PULVERIZER C OUTLET TEMPERATURE 2 | Unit | °C |
| Manufacture | YAMARI | Out. Signal | 4 - 20 mA |
| Model | TM | Max. Deviation | 2 °C |
| Serial Number | 5451744 | Cal. Date | 08-05-2024 |
| Instrument Location | BOILER 2ND FLOOR | Temp. Element | Thermocouple Type E |

Environment Condition

Temperature 31.1 °C
 Humidity 52 % RH

Calibration Result

| Data Reading | | | | | | | | | |
|--------------|------------|------------|-----------|--------|---------|------------|------------|-----------|--------|
| As Found | | | | | As Left | | | | |
| Input | Std Output | Output UUT | Deviation | Result | Input | Std Output | Output UUT | Deviation | Result |
| [°C] | [°C] | [°C] | | | [°C] | [°C] | [°C] | | |
| 40 | 40.020 | 40.000 | -0.020 | Pass | | | | | |
| 50 | 50.000 | 50.200 | 0.200 | Pass | | | | | |
| 100 | 100.000 | 100.100 | 0.100 | Pass | | | | | |
| 150 | 150.020 | 150.900 | 0.880 | Pass | | | | | |
| 200 | 200.020 | 201.100 | 1.080 | Pass | | | | | |

Standard Reference

| Description | Serial Number | Certificate Number | Calibration Date |
|--|----------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 43550006 | S. 22 022 080 | 21-02-2022 |
| DRYBLOCK ADDITEL 875 | 660TH190400016 | S. 23 008 476 /P | 03-07-2023 |

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page

Date of issue, 09-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above
 Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval
 *Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

