

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0606-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC33CT001
Instrument Description PULVERIZER C PYRITE BOX TEMPERATURE
Manufacture -
Model / Serial Number - / -
Instrument Location BOILER 2ND FLOOR

Range 0 ~ 200
Unit °C
Out. Signal 4-20 mA
Max. Deviation 2 °C
Cal. Date 26-05-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 28.9 °C Humidity 86 % RH

Calibration Result

Data Reading									
As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.700	39.800	-0.200	Pass					
50	49.500	49.900	-0.400	Pass					
100	99.800	100.500	-0.400	Pass					
150	151.100	150.800	-0.700	Pass					
200	201.600	201.200	-0.700	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DRY WELL CALIBRATOR ADDITEL 875	660TH210A0009	S-25010821	21-08-2025
Temperature Calibrator Fluke 725	2815000	2256/25/KAL/06/2025	23-06-2025

Calibration Method

0002/SOP_BJS/2025
Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 02-07-2026

Customer Signature,

Erfan Nanda Gifari

HERVITAMA

Approved Signatory,

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person