

CERTIFICATE OF CALIBRATION LEVEL RADAR

Certificate No. : 1117-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC36CL001
Instrument Description PULVERIZER C LOADING OIL TANK LEVEL
Manufacture SIEMENS
Model / Serial Number 7ML 52211BC11 / PDB / KN080864
Instrument Location BOILER GROUND FLOOR
Range 0 ~ 600
Unit mm
Out. Signal 4 - 20 mA
Max. Error 0.5%
Cal. Date 18-06-2026

Environment Condition

Temperature 25 °C Humidity 56 % RH

Calibration Result

Data Reading (Transmitter)												
As Found							As Left					
Input	Std Distance	UUT Distance	Output UUT	Deviation	Error	Result	Input	Std Distance	UUT Distance	Output UUT	Deviation	Error
[mm]	[mm]	[mm]	[mA]		[%]		[mm]	[mm]	[mm]	[mA]		[%]
900	910	908	4.190	-2.000	-0.333	Pass						
750	759	757	8.273	-2.000	-0.333	Pass						
600	611	610	12.145	-1.000	-0.167	Pass						
450	460	460	16.155	0.000	0.000	Pass						
300	305	306	20.260	1.000	0.167	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DIGITAL LASER DISTANCE METER	18H114632	02169/GQI-Sert/03/26	09-03-2026
STEEL TAPE MEASURE	001/L1/HI/2026	01231/GQI-Sert/02/26	09-02-2026

Calibration Method

0006/SOP_BJS/2025
Standard Operating Procedure of Calibration Level Radar / Ultrasound

This certificate comprises 2 pages
Date of issue, 19-06-2026

Customer Signature,



Erfan Nanda Gifari

HERVITAMA



Maul Hasani Ashari

Calibrated by,



Faishol Anwar

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person