

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0161-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC38CP002
Instrument Description PULVERIZER C HYDRAULIC OIL COUNTER PRESSURE 2
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V101498
Instrument Location BOILER 1ST FLOOR

Range 0 ~ 150
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 03-06-2026

Environment Condition

Temperature 32 °C Humidity 70 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
75.010	8.000	8.001	0.001	0.006	Pass						
150.030	12.001	12.001	0.000	0.000	Pass						
225.040	16.002	16.004	0.002	0.013	Pass						
300.060	20.003	20.004	0.001	0.006	Pass						
225.040	16.002	16.003	0.001	0.006	Pass						
150.030	12.001	12.001	0.000	0.000	Pass						
75.010	8.001	8.002	0.001	0.006	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 07-06-2026

Customer Signature,

Erfan Nanda Gifari

Authorized Signatory,

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person