

## REPORT OF INSPECTION ON-OFF VALVE

Certificate No. : 0975-24-HI-CAL-10J

### Customer Information

Company Name: PT. Bhumi Jati Power  
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No.: C-BJP-24-0014-OTH

### Instrument Information

KKS No.: 60HFC53AA201  
 Instrument Description: PYRITE BOX E UPPER GATE  
 Manufacture: -  
 Model: -  
 Serial Number: -  
 Instrument Location: BOILER 1ST FLOOR  
 Damping Time: 0.5 s  
 Inspection Date: 22-05-2024

### Environment Condition

Temperature: 30.9 °C  
 Humidity: 43 % RH  
 Traveling Time  
 Open to Close: 05.64 s  
 Close to Open: 05.06 s

### Stroke Result

| Command | Feedback |       |      |       |
|---------|----------|-------|------|-------|
|         | Local    |       | DCS  |       |
|         | Open     | Close | Open | Close |
| Close   | -        | OK    | -    | OK    |
| Open    | OK       | -     | OK   | -     |

### Visual Inspection

Leak Check:  OK  Not OK  
 Corrosion Condition:  OK  Not OK  
 Air Regulator Check:  OK  Not OK  
 Tightness Check:  OK  Not OK  
 Accessories Check:  OK  Not OK

### Remark

### Test Equipment

Description: STOPWATCH CASIO  
 Serial Number: J011Q03  
 Certificate Number: S. 23 004 599  
 Calibration Date: 27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page  
 Date of issue, 23-05-2024

Customer Signature,

Ayrton Humardani Putradhi

Approved Signatory,

M. Fauziq Nur Fitriyan  
INDONESIA

Calibrated by,

Daday Daryatun

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

