

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0179-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60HFC55CP012  
Instrument Description PULVERIZER E BEARING LUBE OIL PRESSURE 2  
Manufacture HONEYWELL  
Model / Serial Number 5TG745 / C4000005679527  
Instrument Location BOILER 1ST FLOOR

Range 0 ~ 400  
Unit bar  
Out. Signal 4 - 20 mA  
Max. Error 0.5 %  
Cal. Date 06-06-2026

## Environment Condition

Temperature 31 °C Humidity 62 % RH

## Calibration Result

| Data Reading (Transmitter) |            |            |           |       |        |         |            |            |           |       |        |
|----------------------------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| As Found                   |            |            |           |       |        | As Left |            |            |           |       |        |
| Input                      | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [bar]                      | [mA]       | [mA]       |           | [%]   |        | [bar]   | [mA]       | [mA]       |           | [%]   |        |
| 0.000                      | 4.000      | 4.002      | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 100.040                    | 8.001      | 8.005      | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| 200.020                    | 12.000     | 12.007     | 0.007     | 0.044 | Pass   |         |            |            |           |       |        |
| 300.060                    | 16.002     | 16.014     | 0.012     | 0.075 | Pass   |         |            |            |           |       |        |
| 400.030                    | 20.001     | 20.017     | 0.016     | 0.100 | Pass   |         |            |            |           |       |        |
| 300.060                    | 16.002     | 16.011     | 0.009     | 0.056 | Pass   |         |            |            |           |       |        |
| 200.020                    | 12.000     | 12.006     | 0.006     | 0.038 | Pass   |         |            |            |           |       |        |
| 100.040                    | 8.001      | 8.003      | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 0.000                      | 4.000      | 4.002      | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 56070038      | MAL 26031230       | 06-03-2026       |
| FLUKE PRESEURE MODULE 750P31             | 4472839       | MAL 26031236       | 03-03-2026       |

## Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 09-06-2026

Customer Signature,

Erfan Nanda Gifari

HERVITAMA  
Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

