

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0180-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC55CP013
Instrument Description PULVERIZER E BEARING LUBE OIL PRESSURE 3
Manufacture HONEYWELL
Model / Serial Number 5TG745 / C4000005679525
Instrument Location BOILER 1ST FLOOR

Range 0 ~ 400
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 62 % RH

Calibration Result

Data Reading (Transmitter)										
As Found						As Left				
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]
0.000	4.000	4.001	0.001	0.006	Pass					
100.040	8.001	8.004	0.003	0.019	Pass					
200.020	12.000	12.002	0.002	0.013	Pass					
300.060	16.002	16.007	0.005	0.031	Pass					
400.030	20.001	20.013	0.012	0.075	Pass					
300.060	16.002	16.005	0.003	0.019	Pass					
200.020	12.000	12.003	0.003	0.019	Pass					
100.040	8.001	8.004	0.003	0.019	Pass					
0.000	4.000	4.002	0.002	0.013	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 09-06-2026

Customer Signature,

Erfan Nanda Gifari

Authorized Signature,

HERVITAMA
INDONESIA
Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person