

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0186-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFC60CP001
Instrument Description PULVERIZER F OUTLET PRESSURE
Manufacture YOKOGAWA
Model / Serial Number EJX110A / 91V501697
Instrument Location BOILER 3RD FLOOR

Range 0 ~ 350
Unit mbar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 26-05-2026

Environment Condition

Temperature 31 °C Humidity 71 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.000	4.000	3.956	-0.044	-0.275	Pass						
87.500	8.000	7.943	-0.057	-0.356	Pass						
175.000	12.000	11.951	-0.049	-0.306	Pass						
262.500	16.000	15.953	-0.047	-0.294	Pass						
350.000	20.000	19.957	-0.043	-0.269	Pass						
262.500	16.000	15.956	-0.044	-0.275	Pass						
175.000	12.000	11.957	-0.043	-0.269	Pass						
87.500	8.000	7.957	-0.043	-0.269	Pass						
0.000	4.000	3.958	-0.042	-0.263	Pass						

Visual Inspection (Checklist If OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 02-06-2026

Customer Signature,



Erfan Nanda Gifari

Appr. **HERVITAMA**


INDONESIA
Ivan Hasan Ashari

Calibrated by,



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person