

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0206-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE01CF002	Range	0 ~ 62
Instrument Description	PRIMARY AIR FAN A SUCTION AIR FLOW 2	Unit	mbar
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501671	Cal. Date	22-05-2024
Instrument Location	BOILER 2ND FLOOR		

Environment Condition

Temperature 27.2 °C
Humidity 51 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
15.50	8.000	7.997	-0.003	-0.019	Pass						
31.00	12.000	11.998	-0.002	-0.013	Pass						
46.00	16.000	16.001	0.001	0.006	Pass						
62.00	20.000	19.995	-0.005	-0.031	Pass						
62.00	20.000	19.995	-0.005	-0.031	Pass						
46.50	16.000	16.002	0.002	0.012	Pass						
31.00	12.000	11.999	-0.001	-0.006	Pass						
15.50	8.000	8.002	0.002	0.013	Pass						
0.00	4.000	4.002	0.002	0.012	Pass						

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

Calibration Method

0001/SOP_BJS/2023
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
Date of issue, 23-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Eitriyan

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

