

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0210-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFE01CP003	Range	-100 ~ 200
Instrument Description	PRIMARY AIR FAN A INLET AIR PRESSURE 3	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	01V501750	Cal. Date	22-05-2024
Instrument Location	BOILER 2ND FLOOR		

### Environment Condition

Temperature 27.2 °C  
Humidity 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-100	4.000	4.005	0.005	0.031	Pass						
-25	8.000	8.008	0.008	0.050	Pass						
50	12.000	12.006	0.006	0.038	Pass						
125	16.000	16.009	0.009	0.056	Pass						
200	20.000	20.008	0.008	0.050	Pass						
200	20.000	20.008	0.008	0.050	Pass						
125	16.000	16.007	0.007	0.044	Pass						
50	12.000	12.006	0.006	0.038	Pass						
-25	8.000	8.005	0.005	0.031	Pass						
-100	4.000	4.006	0.006	0.038	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
Date of issue, 23-05-2024


Customer Signature,

  
Ayrton Humardani Putradhi

Approved by,

  
M. Taufiq Nur Fitriyan  
INDONESIA

Calibrated by,

  
Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

