

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0570-24-HI-CAL-10D

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HFE01CT003
 Instrument Description PRIMARY AIR FAN A INLET AIR
 TEMPERATURE 3
 Manufacture YAMARI
 Model -
 Serial Number 5451637
 Instrument Location BOILER 2ND FLOOR

Range 0 ~ 100
 Unit °C
 Out. Signal 4 - 20 mA
 Max. Deviation 1.7 °C (JIS)
 Cal. Date 15-05-2024
 Temp. Element Thermocouple Type E

Environment Condition

Temperature 30.7 °C
 Humidity 64 % RH

Calibration Result

Data Reading				
As Found			As Left	
Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]		
40	40.000	40.300	0.300	Pass
45	45.000	45.100	0.100	Pass
50	50.000	50.000	0.000	Pass
75	75.000	75.000	0.000	Pass
100	100.000	100.000	0.000	Pass

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
Dry Block Calibrator Ametek	506481-00011	S.24 - 00201	27-02-2024

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

