

CERTIFICATE OF CALIBRATION

TEMPERATURE SENSOR

Certificate No. : 0662-26-HI-CAL-10

Customer Information

Company NamePT. Bhumi Jati Power

AddressPLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

Contract No.C-BJP-26-0004-OTH

Instrument Information

KKS No.60HFE02CT001

Instrument DescriptionPRIMARY AIR FAN A OUTLET AIR TEMPERATURE

ManufactureYAMARI

Model / Serial Number- / 5451638

Instrument LocationBOILER GROUND FLOOR

Range0 ~ 100

Unit°C

Out. Signal4 - 20 mA

Max. Deviation1.7 °C (JIS)

Cal. Date17-06-2026

Temp. ElementThermocouple Type E

Environment Condition

Temperature31.4 °C

Humidity57 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.900	0.300	Pass					
45	44.600	45.100	0.500	Pass					
50	49.500	50.000	0.500	Pass					
75	74.900	75.200	0.300	Pass					
100	99.900	100.100	0.200	Pass					

Visual Inspection (Checklist if OK)

Leak Check☐

Tightness Check☒

Corrosion Check☒

Accessories Check☒

Power Supply☐

Standard Reference

DescriptionSerial NumberCertificate NumberCalibration Date

DOCUMENTING PROCESS3611011MAL 2603122906-03-2026

DY WEL CALIBRATOR ADDITEL660TH19040016S-2501082222-08-2025

875

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 19-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,




Ivan Hasa

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person