

## REPORT OF INSPECTION MOTORIZED OF VALVE Certificate No. : 0842-24-HI-CAL-10J

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0014-OTH

### Instrument Information

KKS No. 60HFE03AA201 **Power Supply** 380 VAC  
 Instrument Description MILL INLET COLD AIR EXTRACTION DAMPER **Stroke** 225 deg  
 Manufacture AUMA  
 Model SA102-F10 **Inspection Date** 16-05-2024  
 Serial Number 2219MD24197  
 Instrument Location BOILER 2ND FLOOR

### Environment Condition

Temperature 29.9 °C  
 Humidity 44 % RH

### Traveling Time

Open to Close 42.42 s  
 Close to Open 40.38 s

### Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[deg]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

### Visual Inspection

Leak Check  OK  Not OK Tightness Check  OK  Not OK  
 Corrosion Condition  OK  Not OK Accessories Check  OK  Not OK  
 Gearbox Condition  OK  Not OK

### Remark

### Test Equipment

Description	Serial Number	Certificate Number	Calibration Date
Digital Multimeter Fluke 87V	16230349	S. 22 008 274	08-07-2022
STOPWATCH CASIO	J011Q03	S. 23 004 599	27-03-2023

### Inspection Method

0007/SOP\_BJS/2023  
 Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page


Date of issue, 17-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

