

REPORT OF INSPECTION MOTORIZED OF VALVE

Certificate No. : 0843-24-HI-CAL-10J

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-24-0014-OTH

Instrument Information

KKS No. 60HFE05AA201 Power Supply 380 VAC
Instrument Description PRIMARY AIR AH OUTLET DAMPER Stroke 90 deg
Manufacture AUMA
Model SA-14-2-F14 Inspection Date 05-06-2024
Serial Number 2219D4D24161
Instrument Location Turbin Lt. 2

Environment Condition

Temperature 33 °C
Humidity 44 % RH

Traveling Time

Open to Close 56.77 s
Close to Open 57.00 s

Stroke Result

Command	Local	Stroke	DCS FB
[%]	[%]	[mm]	[%]

Command	Feedback			
	Local		DCS	
	Open	Close	Open	Close
Close	-	OK	-	OK
Open	OK	-	OK	-

Visual Inspection

Leak Check OK Not OK Tightness Check OK Not OK
Corrosion Condition OK Not OK Accessories Check OK Not OK
Gearbox Condition OK Not OK

Remark

Test Equipment

Description Serial Number Certificate Number Calibration Date
STOPWATCH CASIO J011Q03 S. 23 004 599 27-03-2023

Inspection Method

0007/SOP_BJS/2023
Procedure of Inspection Pneumatic and MOV

This certificate comprise of 1 page
Date of issue, 06-06-2024

Customer Signature,



Ayrtan Humardani Putradhi

HERVITAMA
Approved Signatory,



M. Taufiq Nur Efdyan

Calibrated by,



Suryo Wicaksono

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

