

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0668-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60HFE06CT001

AIR HEATER OUTLET PRIMARY AIR TEMPERATURE (PULVERIZER HOT AIR TEMPERATURE)

YAMARI

- / -

Boiler 2nd Floor

Range

0 ~ 400

Unit

°C

Out. Signal

4-20 mA

Max. Deviation

4 °C

Cal. Date

29-06-2026

Temp. Element

Thermocouple Type E

Environment Condition

Temperature

29.8 °C

Humidity

55 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.900	39.700	-0.200	Pass					
100	100.100	100.800	0.700	Pass					
200	200.500	201.400	0.900	Pass					
300	301.100	301.800	0.700	Pass					
400	401.600	402.500	0.900	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description
DRY WELL CALIBRATOR ADDITEL
875Serial Number
660TH19040016Certificate Number
S-25010822Calibration Date
22-08-2025

Temperature Calibrator Fluke 725

2815000

2256/25/KAL/06/2025

23-06-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 30-06-2026

Customer Signature,

Erfan Nanda Gifari

HERVITAMA

Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

