

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0474-24-HI-CAL-10C

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No.	60HFE07CP001	Range	0 ~ 100
Instrument Description	PRIMARY AIR FAN A CONTROL OIL PRESSURE 1	Unit	barg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX430A	Max. Error	0.5 %
Serial Number	91V501751	Cal. Date	17-05-2024
Instrument Location	BOILER PA FAN		

Environment Condition

Temperature 31.5 °C
 Humidity 66 % RH

Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
25.03	8.005	8.003	-0.002	-0.013	Pass						
50.06	12.009	12.008	-0.001	-0.006	Pass						
75.01	16.002	16.003	0.001	0.006	Pass						
100.04	20.006	20.002	-0.004	-0.025	Pass						
100.04	20.006	20.002	-0.004	-0.025	Pass						
75.01	16.002	16.006	0.004	0.025	Pass						
50.06	12.009	12.000	-0.009	-0.056	Pass						
25.03	8.005	8.007	0.002	0.012	Pass						
0.00	4.000	4.000	0.000	0.000	Pass						

Standard Reference


Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter


This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person