

## CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0475-24-HI-CAL-10C

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-0TH

### Instrument Information

|                        |                                          |             |            |
|------------------------|------------------------------------------|-------------|------------|
| KKS No.                | 60HFE07CP002                             | Range       | 0 – 100    |
| Instrument Description | PRIMARY AIR FAN A CONTROL OIL PRESSURE 2 | Unit        | barg       |
| Manufacture            | YOKOGAWA                                 | Out. Signal | 4 - 20 mA  |
| Model                  | EJX430A                                  | Max. Error  | 0.5 %      |
| Serial Number          | 91V5011752                               | Cal. Date   | 17-05-2024 |
| Instrument Location    | BOILER PA FAN                            |             |            |

### Environment Condition

Temperature 31.5 °C  
 Humidity 66 % RH

### Calibration Result

| As Found |            |            |           |        |        | As Left |            |            |           |       |        |
|----------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| Input    | Std Output | Output UUT | Deviation | Error  | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [barg]   | [mA]       | [mA]       |           | [%]    |        | [barg]  | [mA]       | [mA]       |           | [%]   |        |
| 0.00     | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |
| 25.03    | 8.005      | 8.007      | 0.002     | 0.012  | Pass   |         |            |            |           |       |        |
| 50.06    | 12.009     | 12.005     | -0.004    | -0.025 | Pass   |         |            |            |           |       |        |
| 75.01    | 16.002     | 15.994     | -0.008    | -0.050 | Pass   |         |            |            |           |       |        |
| 100.04   | 20.006     | 19.996     | -0.010    | -0.063 | Pass   |         |            |            |           |       |        |
| 100.04   | 20.006     | 19.996     | -0.010    | -0.063 | Pass   |         |            |            |           |       |        |
| 75.01    | 16.002     | 16.001     | -0.001    | -0.006 | Pass   |         |            |            |           |       |        |
| 50.06    | 12.009     | 12.000     | -0.009    | -0.056 | Pass   |         |            |            |           |       |        |
| 25.03    | 8.005      | 8.002      | -0.003    | -0.019 | Pass   |         |            |            |           |       |        |
| 0.00     | 4.000      | 4.000      | 0.000     | 0.000  | Pass   |         |            |            |           |       |        |

### Standard Reference

| Description                              | Serial Number | Certificate Number | Calibration Date |
|------------------------------------------|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011       | S. 22 011 747      | 23-09-2023       |
| PRESSURE MODULE P31                      | 4472839       | S. 23 004 595      | 27-03-2023       |

### Calibration Method

0001/SOP\_BJS/2023  
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page  
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

HERVITAMA  
 Approved Signatory,



M. Taufiq Nur Fitriyan  
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

