

CERTIFICATE OF CALIBRATION
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0210-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE07CP003
Instrument Description PRIMARY AIR FAN A CONTROL OIL PRESSURE 3
Manufacture YOKOGAWA
Model / Serial Number EJX430A / 91V5011753
Instrument Location BOILER PA FAN

Range 0 ~ 100
Unit bar
Out. Signal 4 - 20 mA
Max. Error 0.5 %
Cal. Date 06-06-2026

Environment Condition

Temperature 31 °C Humidity 62 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[bar]	[mA]	[mA]		[%]		[bar]	[mA]	[mA]		[%]	
0.000	4.000	4.001	0.001	0.006	Pass						
25.030	8.004	8.002	-0.002	-0.013	Pass						
50.060	12.009	12.006	-0.003	-0.019	Pass						
75.010	16.001	16.005	0.004	0.025	Pass						
100.040	20.006	20.008	0.002	0.013	Pass						
75.010	16.001	16.001	0.000	0.000	Pass						
50.060	12.009	12.006	-0.003	-0.019	Pass						
25.030	8.004	8.006	0.002	0.013	Pass						
0.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	56070038	MAL 26031230	06-03-2026
FLUKE PRESEURE MODULE 750P31	4472839	MAL 26031236	03-03-2026

Calibration Method

0001/SOP_BJS/2025
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
Date of issue, 09-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

INDONESIA

Ivan Hasan Ashari

Calibrated by,

Akhmad Nashoikhuddin

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person