

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0672-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No.	60HFE07CT004	Range	0 ~ 150
Instrument Description	PRIMARY AIR FAN A THRUST BEARING TEMPERATURE HIGH (NON-MOTOR SIDE)	Unit	°C
Manufacture	YAMARI	Out. Signal	4 - 20 mA
Model / Serial Number	TM / 5451265	Max. Deviation	1.7 °C (JIS)
Instrument Location	PA FAN A	Cal. Date	02-06-2026
		Temp. Element	Thermocouple Type E

Environment Condition

Temperature 28.1 °C Humidity 54 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.800	0.200	Pass					
60	59.600	60.200	0.600	Pass					
90	89.900	90.800	0.900	Pass					
120	120.200	121.000	0.800	Pass					
150	150.500	150.000	-0.500	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS	3611011	MAL 26031229	06-03-2026
CALIBRATOR FLUKE 754			
DRY BLOCK CALIBRATOR	61640200865	3835/25/EX/09/2025	09-09-2025
AMETEK			

Calibration Method

001 / Service-HI / 2019
Standard Operating Procedure of Pressure Transmitter Calibration

This certificate comprises 2 pages
Date of issue, 06-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person