

## CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0428-24-HI-CAL-10C

### Customer Information

Company Name: PT. Bhumi Jati Power  
Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No.: C-BJP-24-0013-OTH

### Instrument Information

KKS No.	60HFE10CP003	Range	-50 ~ 250
Instrument Description	PULVERIZER A DIFFERENTIAL PRESSURE 2	Unit	mbarg
Manufacture	YOKOGAWA	Out. Signal	4 - 20 mA
Model	EJX110A	Max. Error	0.5 %
Serial Number	91V501615	Cal. Date	25-05-2024
Instrument Location	BOILER 3RD FLOOR		

### Environment Condition

Temperature: 27.3 °C  
Humidity: 50 % RH

### Calibration Result

Data Reading (Transmitter)											
As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbarg]	[mA]	[mA]		[%]		[mbarg]	[mA]	[mA]		[%]	
-50	4.000	4.000	0.000	0.000	Pass						
25	8.000	7.999	-0.001	-0.006	Pass						
100	12.000	12.003	0.003	0.019	Pass						
175	16.000	15.999	-0.001	-0.006	Pass						
250	20.000	20.002	0.002	0.012	Pass						
250	20.000	20.002	0.002	0.012	Pass						
175	16.000	16.000	0.000	0.000	Pass						
100	12.000	12.002	0.002	0.013	Pass						
25	8.000	8.003	0.003	0.019	Pass						
-50	4.000	4.001	0.001	0.006	Pass						

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	56070038	S. 22 002 081	17-02-2022
Pressure Module Fluke 750PD4	4474073	S. 23 014 461	10-10-2023

### Calibration Method

0001/SOP\_BJS/2023  
Procedure of Calibration Pressure & Differential Transmitter


This certificate comprise of 1 page  
Date of issue, 26-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan

INDONESIA

Calibrated by,



Alfidin Rachmansyah

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

