

CERTIFICATE OF CALIBRATION DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0222-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE11CP002
 Instrument Description PRIMARY AIR FAN B INLET AIR PRESSURE 2
 Manufacture YOKOGAWA
 Model / Serial Number EJX430A / 91V501767
 Instrument Location BOILER 2ND FLOOR

Range -50 ~ 250
 Unit mbar
 Out. Signal 4 - 20 mA
 Max. Error 0.5 %
 Cal. Date 30-05-2026

Environment Condition

Temperature 31 °C Humidity 70 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[mbar]	[mA]	[mA]		[%]		[mbar]	[mA]	[mA]		[%]	
-100.000	4.000	3.999	-0.001	-0.006	Pass						
-25.000	8.000	7.999	-0.001	-0.006	Pass						
50.000	12.000	12.001	0.001	0.006	Pass						
125.000	16.000	16.000	0.000	0.000	Pass						
200.000	20.000	20.002	0.002	0.013	Pass						
125.000	16.000	16.001	0.001	0.006	Pass						
50.000	12.000	12.000	0.000	0.000	Pass						
-25.000	8.000	7.999	-0.001	-0.006	Pass						
-100.000	4.000	4.000	0.000	0.000	Pass						

Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒
 Accessories Check ☒ Power Supply ☒

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	2448033	4482/25/EX/10/2025	26-09-2025
FLUKE PRESURE MODULE 750PD4	4474073	02171/GQI-Sert/03/26	09-03-2026

Calibration Method

0001/SOP_BJS/2025
 Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages
 Date of issue, 04-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Ashari

Calibrated by,



Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person