

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0572-24-HI-CAL-10D

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60HFE11CT002
 Instrument Description: PRIMARY AIR FAN B INLET AIR TEMPERATURE 2
 Manufacture: YAMARI
 Model: -
 Serial Number: 5451644
 Instrument Location: BOILER 2ND FLOOR

Range: 0 ~ 100
 Unit: °C
 Out. Signal: 4 - 20 mA
 Max. Deviation: 1.7 °C (JIS)
 Cal. Date: 15-05-2024
 Temp. Element: Thermocouple Type E

Environment Condition

Temperature: 28.5 °C
 Humidity: 74 % RH

Calibration Result

As Found					Data Reading					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.100	0.100	Pass										
45	45.000	45.100	0.100	Pass										
50	50.100	50.100	0.000	Pass										
75	75.000	75.300	0.300	Pass										
100	100.000	100.500	0.500	Pass										

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Callibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

Calibration Method

0002/SOP_BJS/2023
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page
 Date of issue, 16-05-2024

Customer Signature,




Ayrtan Humardani Putradhi

Approved Signatory,



M. Jauq Nur Fitriyan

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia

It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

