

## CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0573-24-HI-CAL-10D

### Customer Information

Company Name PT. Bhumi Jati Power  
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
 Contract No. C-BJP-24-0013-OTH

### Instrument Information

KKS No. 60HFE11CT003  
 Instrument Description PRIMARY AIR FAN B INLET AIR TEMPERATURE 3  
 Manufacture YAMARI  
 Model -  
 Serial Number 5451645  
 Instrument Location BOILER 2ND FLOOR

Range 0 ~ 100  
 Unit °C  
 Out. Signal 4 - 20 mA  
 Max. Deviation 1.7 °C (JIS)  
 Cal. Date 15-05-2024  
 Temp. Element Thermocouple Type E

### Environment Condition

Temperature 29 °C  
 Humidity 73 % RH

### Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	40.000	40.000	0.000	Pass					
45	45.000	45.000	0.000	Pass					
50	50.010	50.100	0.090	Pass					
75	75.080	75.500	0.420	Pass					
100	100.000	100.800	0.800	Pass					

### Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	43550006	S. 22 022 080	21-02-2022
DRYBLOCK ADDITEL 875	660TH190400016	S. 23 008 476 /P	03-07-2023

### Calibration Method

0002/SOP\_BJS/2023  
 Procedure of Calibration Temperature Element and Temperature Transmitter

This certificate comprise of 1 page  
 Date of issue, 16-05-2024

Customer Signature,




Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fihyan  
 INDONESIA

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

*This certificate applies only for the item specified above*

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia  
*It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval*

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

*This certificate is valid if it has approved and signed by authorized person*

