

CERTIFICATE OF CALIBRATION TEMPERATURE SENSOR

Certificate No. : 0675-26-HI-CAL-10

Customer Information

Company Name PT. Bhumi Jati Power
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
Contract No. C-BJP-26-0004-OTH

Instrument Information

KKS No. 60HFE11CT003
Instrument Description PRIMARY AIR FAN B INLET AIR TEMPERATURE 3
Manufacture YAMARI
Model / Serial Number - / 5451645
Instrument Location BOILER 2ND FLOOR

Range 0 ~ 100
Unit °C
Out. Signal 4 - 20 mA
Max. Deviation 1.7 °C (JIS)
Cal. Date 31-05-2026
Temp. Element Thermocouple Type E

Environment Condition

Temperature 24.3 °C Humidity 87 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	39.800	0.200	Pass					
45	44.600	44.700	0.100	Pass					
50	49.500	49.600	0.100	Pass					
75	74.920	74.800	-0.120	Pass					
100	99.920	99.500	-0.420	Pass					

Visual Inspection (Checklist if OK)

Leak Check ☐ Tightness Check ☒ Corrosion Check ☒
Accessories Check ☒ Power Supply ☐

Standard Reference

Description	Serial Number	Certificate Number	Calibration Date
DOCUMENTING PROCESS CALIBRATOR FLUKE 754	3611011	MAL 26031229	06-03-2026
DRY WELL CALIBRATOR ADDITEL 875	660TH19040016	S-25010822	22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages
Date of issue, 01-06-2026

Customer Signature,



Erfan Nanda Gifari

Approved Signatory,



Ivan Hasan Ashari

Calibrated by,



Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person