

CERTIFICATE OF CALIBRATION
TEMPERATURE SENSOR

Certificate No. : 0680-26-HI-CAL-10

Customer Information

Company Name

Address

Contract No.

PT. Bhumi Jati Power

PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah

C-BJP-26-0004-OTH

Instrument Information

KKS No.

Instrument Description

Manufacture

Model / Serial Number

Instrument Location

60HFE15CT002

AIR HEATER B OUTLET PRIMARY TEMPERATURE 2

YAMARI

- / 5451640

Boiler 2nd Floor

Range

Unit

Out. Signal

Max. Deviation

Cal. Date

Temp. Element

0 ~ 400

°C

4-20 mA

4 °C

23-06-2026

Thermocouple Type E

Environment Condition

Temperature

29.3 °C

Humidity

51 % RH

Calibration Result

As Found					As Left				
Input	Std Output	Output UUT	Deviation	Result	Input	Std Output	Output UUT	Deviation	Result
[°C]	[°C]	[°C]			[°C]	[°C]	[°C]		
40	39.600	40.100	0.500	Pass					
100	99.800	101.800	2.000	Pass					
200	201.500	201.100	-0.400	Pass					
300	301.200	301.400	0.200	Pass					
400	401.100	401.500	0.400	Pass					

Visual Inspection (Checklist if OK)

Leak Check



Tightness Check



Corrosion Check



Accessories Check



Power Supply



Standard Reference

Description

Temperature Calibrator Fluke 725
DRY WELL CALIBRATOR ADDITEL
875

Serial Number

2815000
660TH19040016

Certificate Number

2256/25/KAL/06/2025
S-25010822

Calibration Date

23-06-2025
22-08-2025

Calibration Method

0002/SOP_BJS/2025

Standard Operating Procedure of Calibration Temperature Element, Temperature Transmitter & Temperature Switch

This certificate comprises 2 pages

Date of issue, 24-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

HERVITAMA
INDONESIA

Ivan Hasan Ashari

Calibrated by,

Khabib Mundzirul Umam

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person