

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0217-24-HI-CAL-10C

Customer Information

Company Name: PT. Bhumi Jati Power
 Address: PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No.: C-BJP-24-0013-OTH

Instrument Information

KKS No.: 60HFE17CP001
 Instrument Description: PRIMARY AIR FAN B CONTROL OIL PRESSURE 1
 Manufacture: YOKOGAWA
 Model: EJX430A
 Serial Number: 91V501769
 Instrument Location: BOILER PA FAN

Range: 0 ~ 100
 Unit: barg
 Out. Signal: 4 - 20 mA
 Max. Error: 0.5 %
 Cal. Date: 17-05-2024

Environment Condition

Temperature: 31.5 °C
 Humidity: 66 % RH

Calibration Result

| Data Reading (Transmitter) | | | | | | As Left | | | | | |
|----------------------------|------------|------------|-----------|--------|--------|---------|------------|------------|-----------|-------|--------|
| As Found | | | | | | As Left | | | | | |
| Input | Std Output | Output UUT | Deviation | Error | Result | Input | Std Output | Output UUT | Deviation | Error | Result |
| [barg] | [mA] | [mA] | | [%] | | [barg] | [mA] | [mA] | | [%] | |
| 0.00 | 4.000 | 4.000 | 0.000 | 0.000 | Pass | | | | | | |
| 25.03 | 8.005 | 8.001 | -0.004 | -0.025 | Pass | | | | | | |
| 50.06 | 12.009 | 12.007 | -0.002 | -0.013 | Pass | | | | | | |
| 75.01 | 16.002 | 16.002 | 0.000 | 0.000 | Pass | | | | | | |
| 100.04 | 20.006 | 20.007 | 0.001 | 0.006 | Pass | | | | | | |
| 100.04 | 20.006 | 20.007 | 0.001 | 0.006 | Pass | | | | | | |
| 75.01 | 16.002 | 16.001 | -0.001 | -0.006 | Pass | | | | | | |
| 50.06 | 12.009 | 12.007 | -0.002 | -0.013 | Pass | | | | | | |
| 25.03 | 8.005 | 7.993 | -0.012 | -0.075 | Pass | | | | | | |
| 0.00 | 4.000 | 4.000 | 0.000 | 0.000 | Pass | | | | | | |

Standard Reference

| Description | Serial Number | Certificate Number | Calibration Date |
|--|---------------|--------------------|------------------|
| Documenting Process Calibrator Fluke 754 | 3611011 | S. 22 011 747 | 23-09-2023 |
| PRESSURE MODULE P31 | 4472839 | S. 23 004 595 | 27-03-2023 |

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approved Signatory,



M. Taufiq Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas
 This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang
 This certificate is valid if it has approved and signed by authorized person

