

CERTIFICATE OF CALIBRATION PRESSURE TRANSMITTER

Certificate No. : 0218-24-HI-CAL-10C

Customer Information

Company Name PT, Bhumi Jati Power
 Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah
 Contract No. C-BJP-24-0013-OTH

Instrument Information

KKS No. 60HFE17CP002
 Instrument Description PRIMARY AIR FAN B CONTROL OIL PRESSURE 2
 Manufacture YOKOGAWA
 Model EJX430A
 Serial Number 91V501770
 Instrument Location BOILER PA FAN

Range 0 - 100
 Unit barg
 Out. Signal 4 - 20 mA
 Max. Error 0.5 %
 Cal. Date 17-05-2024

Environment Condition

Temperature 31.5 °C
 Humidity 66 % RH

Calibration Result

As Found						As Left					
Input	Std Output	Output UUT	Deviation	Error	Result	Input	Std Output	Output UUT	Deviation	Error	Result
[barg]	[mA]	[mA]		[%]		[barg]	[mA]	[mA]		[%]	
0.00	4.000	4.000	0.000	0.000	Pass						
25.03	8.005	7.996	-0.009	-0.056	Pass						
50.06	12.009	12.001	-0.008	-0.050	Pass						
75.01	16.002	16.000	-0.002	-0.012	Pass						
100.04	20.006	20.002	-0.004	-0.025	Pass						
100.04	20.006	20.002	-0.004	-0.025	Pass						
75.01	16.002	16.002	0.000	0.000	Pass						
50.06	12.009	12.009	0.000	0.000	Pass						
25.03	8.005	8.005	0.000	0.000	Pass						
0.00	4.000	3.999	-0.001	-0.006	Pass						

Standard Reference


Description	Serial Number	Certificate Number	Calibration Date
Documenting Process Calibrator Fluke 754	3611011	S. 22 011 747	23-09-2023
PRESSURE MODULE P31	4472839	S. 23 004 595	27-03-2023

Calibration Method

0001/SOP_BJS/2023
 Procedure of Calibration Pressure & Differential Transmitter

This certificate comprise of 1 page
 Date of issue, 18-05-2024

Customer Signature,



Ayrton Humardani Putradhi

Approve by,



M. Raufi Nur Fitriyan
 INDONESIA

Calibrated by,



Handi Suryawinata

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Dilarang mengutip, memperbanyak dan / atau mempublikasikan isi sertifikat ini tanpa izin dari PT. Hervitama Indonesia
 It is prohibited to copy, reproduce and / or publish the content of this Certificate without PT Hervitama Indonesia's approval

*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person

