

CERTIFICATE OF CALIBRATION  
DIFFERENTIAL PRESSURE TRANSMITTER

Certificate No. : 0228-26-HI-CAL-10

## Customer Information

Company Name PT. Bhumi Jati Power  
Address PLTU Tanjung Jati B Unit 5&6 Tubanan, Kembang, Jepara - Jawa Tengah  
Contract No. C-BJP-26-0004-OTH

## Instrument Information

KKS No. 60HFE17CP004 Range 200 ~ 2000  
Instrument Description PRIMARY AIR FAN B LUBE OIL PRESSURE 1 Unit mbar  
Manufacture YOKOGAWA Out. Signal 4 - 20 mA  
Model / Serial Number EJX430A / 91V501772 Max. Error 0.5 %  
Instrument Location BOILER 1ST FLOOR Cal. Date 01-06-2026

## Environment Condition

Temperature 31 °C Humidity 72 % RH

## Calibration Result

| As Found |            |            |           |       |        | As Left |            |            |           |       |        |
|----------|------------|------------|-----------|-------|--------|---------|------------|------------|-----------|-------|--------|
| Input    | Std Output | Output UUT | Deviation | Error | Result | Input   | Std Output | Output UUT | Deviation | Error | Result |
| [mbar]   | [mA]       | [mA]       |           | [%]   |        | [mbar]  | [mA]       | [mA]       |           | [%]   |        |
| 200.000  | 4.000      | 4.004      | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| 650.000  | 8.000      | 8.003      | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| 1100.000 | 12.000     | 12.003     | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| 1550.000 | 16.000     | 16.003     | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| 2000.000 | 20.000     | 20.002     | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 1550.000 | 16.000     | 16.002     | 0.002     | 0.013 | Pass   |         |            |            |           |       |        |
| 1100.000 | 12.000     | 12.004     | 0.004     | 0.025 | Pass   |         |            |            |           |       |        |
| 650.000  | 8.000      | 8.003      | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |
| 200.000  | 4.000      | 4.003      | 0.003     | 0.019 | Pass   |         |            |            |           |       |        |

## Visual Inspection (Checklist if OK)

Leak Check ☒ Tightness Check ☒ Corrosion Check ☒  
Accessories Check ☒ Power Supply ☒

## Standard Reference

| Description                              | Serial Number | Certificate Number   | Calibration Date |
|------------------------------------------|---------------|----------------------|------------------|
| DOCUMENTING PROCESS CALIBRATOR FLUKE 754 | 2448033       | 4482/25/EX/10/2025   | 26-09-2025       |
| FLUKE PRESURE MODULE 700P05              | 14270508      | 02837/GQI-Sert/04/26 | 13-04-2026       |

## Calibration Method

0001/SOP\_BJS/2025  
Standard Operating Procedure of Calibration Pressure & Differential Transmitter

This certificate comprises 2 pages  
Date of issue, 05-06-2026

Customer Signature,

Erfan Nanda Gifari

Approved Signatory,

  
HERVITAMA  
INDONESIA  
Ivan Hasan Ashari

Calibrated by,

Ryan Franki Risdianto

Sertifikat ini berlaku untuk alat dengan nama, merek dan tipe / nomor seri yang dinyatakan diatas

This certificate applies only for the item specified above

Tidak dibenarkan mempublikasikan/memperbanyak sebagian isi sertifikat ini tanpa ijin PT. Hervitama Indonesia

This certificate shall not be produced/reproduced except in full without the written approval of PT. Hervitama Indonesia

\*Sertifikat ini sah bila dibubuhi cap PT. Hervitama Indonesia dan ditandatangani oleh pejabat yang berwenang

This certificate is valid if it has approved and signed by authorized person